Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE KERB STONE

Lab ID : **CP-2018-01-09-02** **Date: 13-01-18**

Customer : Assistant Executive Engineer, Yelahanka New Town Sub Division, BBMP, Bangalore,

Address : Yelahanka New Town Sub Division, BBMP, Bangalore,

Project Name : Engagement of Gangman and Hiring of Tractor, Tippers for cleaning and Maintenance of road side drains and others cleaning works in ward no.04.

Agency : Sri.N Suresh, No.14, 1st main, 3rd Cross, Goraguntepalya, Banglore.

Customer's Reference : EE(YNK.D)E-PMT-06/W.O/000064/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 09-01-18

Sample ID No : 2018-01-09-02/01

Sample Type /Size : CC Kerb Stone/ 450*165*400mm

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete

Date of test : 09/01/2018

SL No.	Identification Mark	Diameter of the core	Height of the core	Weight of the core	Area	Failure Load	Core Compressive strength	Corrected Cylinder Compressive strength	Equivalent Cube Compressive strength
		(mm)	(mm)	Kg	(Sq.mm)	(KN)	(N/mm2)	(N/mm2)	(N/mm2)
1	A	100.02	165.51	2.917	7856	151.3	19.3	19.3	24.1
2	B	100.01	165.52	2.854	7854	154.8	19.7	19.7	24.6
3	C	100.02	165.49	2.842	7856	155.3	19.8	19.8	24.7

Note:

The results pertain to the samples received and tested.
All information furnished by the Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AB-4
13/01/18

CIVIL Pro Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

****End of Report****

Format No: CP/TF/01

TEST REPORT OF PRECAST COVER SLAB

Lab ID : CP-2018-01-09-02

Date: 13-01-18

Customer : Assistant Executive Engineer, Yelahanka New Town Sub Division, BBMP, Bangalore,

Address : Yelahanka New Town Sub Division, BBMP, Bangalore,

Project Name : Engagement of Gangman and Hiring of Tractor, Tippers for cleaning and Maintenance of road side drains and others cleaning works in ward no.04.

Agency : Sri.N Suresh, No.14, 1st main, 3rd Cross, Goraguntepalya, Banglore.

Customer's Reference : EE(YNK.D)E-PMT-06/W.O/000064/2017-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 09-01-18

Sample ID No : 2018-01-09-02/02

Sample Type /Size : Precast Cover Slab

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete

Date of test : 09/01/2018

Sl. No.	Identification Mark	Diameter of the core	Height of the core	Weight of the core	Area	Failure Load	Core Compressive strength	Corrected Cylinder Compressive strength	Equivalent Cube Compressive strength
		(mm)	(mm)	(kg)	(Sq.mm)	(KN)	(N/mm^2)	(N/mm^2)	(N/mm^2)
1	Cover Slab-1	75.13	100.51	1.351	4432	75.9	17.1	15.9	19.9
2	Cover Slab-2	75.22	100.49	1.384	4443	81.2	18.3	17.0	21.2
3	Cover Slab-3	75.31	100.52	1.361	4454	78.6	17.6	16.4	20.5

Note:
The results pertain to the samples received and tested.
All information furnished by the Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO BANGALORE Sig..... Date.....

FOR CIVIL Pro.

R RUDRAPRASAD
Authorized Signatory
Technical Manager

****End of Report****